



AC 063

CENTRUM NAUKOWO-BADAWCZE
OCHRONY PRZECIWPOŻAROWEJ
im. Józefa Tuliszkowskiego
PAŃSTWOWY INSTYTUT BADAWCZY
ul. Nadwiślańska 213, 05-420 Józefów k/Otwocka



CERTIFICATE OF ADMITTANCE

No. 5856/2025

Based on art. 7 paragraph 2 of the Act of 24 August 1991 on fire protection
Centrum Naukowo-Badawcze Ochrony Przeciwpożarowej im. Józefa Tuliszkowskiego
Państwowy Instytut Badawczy at the request of:

ATM Lighting sp. z o.o.
ul. Maszynowa 30A
80-298 Gdańsk

states that product:

Emergency lighting luminaire type EXF400LED
Varieties of the luminaire are given on page 2 of this certificate of admittance.

manufactured by:

ATM Lighting sp. z o.o.
ul. Maszynowa 30A
80-298 Gdańsk

in the manufacturing plant:

ATM Lighting sp. z o.o.
ul. Maszynowa 30A
80-298 Gdańsk

meets the requirements of:

p. 13.2 of annex to the Regulation of the Minister of the Interior and Administration of 20 June 2007 on the list of products used for ensuring public safety or protecting health, life and property, and the principles of issuing admittance to use these products (Polish Journal of Laws: Dz. U. nr 143 poz. 1002; zm.: Dz. U. z 2010 r. nr 85, poz. 553, z 2018 r. poz. 984, z 2022 r. poz. 2282)

Documentation:

1. Application for the process of product admittance No. 7189/2023 of 29.08.2023.
2. Test report No. 954/BA/25 of 01.09.2025 prepared by Zespół Laboratoriów Sygnalizacji Alarmu Pożaru i Automatyki Pożarniczej (BA) CNBOP-PIB.


The certificate of admittance is valid under the condition that the applicant fulfils the requirements defined in the agreement No. 5856/DC/CNBOP-PIB/2025.

Validity period of the admittance:

from **27.10.2025**

until **26.10.2030**

DIRECTOR OF CNBOP-PIB


pp Deputy Director for Certification and Admittance
st. bryg. Jacek Zboina, D.Sc. Eng.



Józefów: 27 October 2025

*This document was originally translated from Polish to English on 29 December 2025.
In case of conflict between the Polish certificate of admittance and this translation, the Polish document shall be binding.*



AC 063

**CENTRUM NAUKOWO-BADAWCZE
OCHRONY PRZECIWPOŻAROWEJ**

im. Józefa Tuliszowskiego

PAŃSTWOWY INSTYTUT BADAWCZY

ul. Nadwiślańska 213, 05-420 Józefów k/Otwocka



CERTIFICATE OF ADMITTANCE

No. 5856/2025

TECHNICAL DATA IDENTIFYING THE PRODUCT

Emergency lighting luminaire type EXF400LED in varieties:

Type	Length series	LED module type	Control current	Voltage	Connection	Recesses	Housing material	Lens material	Emergency version	Control	Three-phase version	Bracket			
EXF400LED	0600	FC1 FC2	---	24E	40 60	10 20	P20 P25 M20 M25	ALU	GL PC	---	DA	---	3F	AMOA AMOB AMOC AMOE AMOF AMOG	
	1200	FC2	---	24E											A3
	0600	FC1 FC2	---	25E	30 33 50 55	10 11 20 21									ZB
	1200	FC2 FC4	---	25E	70 77	21 22									
	0600	FC1 FC2	1 2 3	34E	40 60 80	10 20									A3
	1200	FC2 FC4	1 2 3	34E											
	0600	FC1 FC2	1 2 3	35E	30 33	10 11									ZB
	1200	FC2 FC4	2 3	35E	50 55 70 77	20 21 22									
	0600	FC1 FC2	2 3	36E											
	1200	FC2 FC4	2 3	36E											
	0600	FC2	---	44E	40 60 80	10 20									A1
	1200	FC2	---	44E											
	0600	FC1 FC2	---	45E	30 33 50 55	10 11 20 21									ZB
	1200	FC2 FC4	---	45E	70 77	21 22									

DIRECTOR OF CNBOP-PIB

Jhano

pp Deputy Director for Certification and Admittance
st. bryg. Jacek Zboina, D.Sc. Eng.



Józefów: 27 October 2025

*This document was originally translated from Polish to English on 29 December 2025.
In case of conflict between the Polish certificate of admittance and this translation, the Polish document shall be binding.*



AC 063

**CENTRUM NAUKOWO-BADAWCZE
OCHRONY PRZECIWPOŻAROWEJ**
im. Józefa Tuliszковского
PAŃSTWOWY INSTYTUT BADAWCZY
ul. Nadwiślańska 213, 05-420 Józefów k/Otwocka



CERTIFICATE OF ADMITTANCE

No. 5856/2025

TECHNICAL DATA IDENTIFYING THE PRODUCT

Emergency lighting luminaire type EXF400LED

Varieties of the luminaire are given on page 2 of this certificate of admittance.

Type	EXF400LED	
	Z – central supply	X – self-contained
Operation mode:	0 - non-maintained; 1 – maintained;	0 - non-maintained; 1 – maintained;
Accessories	E - with non-replaceable lamp; G - internally illuminated safety sign (optional);	E - with non-replaceable lamp F – automatic test gear complying with IEC 61347-2-7 denoted EL-T G - internally illuminated safety sign (optional);
Rated emergency operating time	not applicable (parameter of power systems)	90 - 1,5 hours of emergency operating time (A1) 120 - 2 hours of emergency operating time (A3)
Rated supply voltage	110÷254V AC 50÷60Hz, 220÷250V DC 220÷240V AC 50÷60Hz, 110÷127V AC 50÷60Hz, 110÷127V DC	110÷254V AC 50÷60Hz 220÷240V AC 50÷60Hz 110÷127V AC 50÷60Hz
Protection class against electric shock	I	
Ingress protection rating to dust, solids and water	IP66/67	
Light source	LED module	
Battery charging time	not applicable (parameter of power systems)	not exceeding 24 h
Battery charging indication	not applicable (function of power systems)	yes – LED diode
Adapted to pictograms	yes (optional)	
Mounting method	surface	
Mounting surface (in accordance with PN-EN 60598-1)	normally flammable surfaces	
Conditions of use (in accordance with PN-EN 60598-1)	for normal use	
Material of housing	metal	
<i>Self-contained luminaires are intended for automatic testing systems in accordance with the PN-EN 62034:2012 standard.</i>		


ADDITIONAL TERMS AND COMMENTS:

According to § 17 of the Regulation of the Minister of the Interior and Administration of 20 June 2007 on the list of products used for ensuring public safety or protecting health, life and property, and the principles of issuing admittance to use these products (Polish Journal of Laws: Dz. U. nr 143 poz. 1002; zm.: Dz. U. z 2010 r. nr 85, poz. 553, z 2018 r. poz. 984, z 2022 r. poz. 2282) a product should be marked with the marking of the admittance body and also the number of the certificate of admittance.

The following editions of the standards were used in the admittance process:

- PN-EN IEC 60598-2-22:2022-11
- PN-EN IEC 60598-1:2021-07+A1+A11:2022-12

DIRECTOR OF CNBOP-PIB


pp Deputy Director for Certification and Admittance
st. brig. Jacek Zboina, D.Sc. Eng.



Józefów: 27 October 2025

This document was originally translated from Polish to English on 29 December 2025.
In case of conflict between the Polish certificate of admittance and this translation, the Polish document shall be binding.